



HYMAX[®] COUPLING

HYMAX[®]
Repair the past. Connect the future.

APPENDIX TO INSTALLATION INSTRUCTIONS

DO NOT DISASSEMBLE THE COUPLING. DO NOT LUBRICATE THE BOLTS.

When using the HYMAX Coupling with an insulating boot/sleeve for additional corrosion control:

Place the insulating boot/sleeve (not provided by Krausz) on one pipe end and the coupling on the other pipe end. Install the HYMAX Coupling according to the installation instructions.

Although Krausz does not offer an insulating boot/sleeve to be used with HYMAX products, all standard warranty terms in effect at the time of installation will apply to any product manufactured by Krausz.


NOTE: the insulating boot/sleeve adds up to .30" to the outside diameter (OD) of the host pipe, depending on the manufacturer.

KRAUSZ USA. 331 SW 57TH AVENUE, OCALA, FLORIDA 34474 • INFO@KRAUSZUSA.COM

FOR ORDERING INFORMATION OR TO SPEAK WITH A KRAUSZ REPRESENTATIVE PLEASE CONTACT US AT:
855-457-2879 OR 855-4KRAUSZ. • FAX 352-304-5787 • WWW. KRAUSZUSA.COM

HYMAX[®] is a registered trademark of Krausz Industries Ltd.

0002-2000-900 REV C

 **KRAUSZ** is the creator of HYMAX